



GENERAL NOTES


1. EXISTG CONDITIONS ARE BASED ON AVAILABLE INFORMATION. PRIOR TO SUBMITTING A BID, THE CONTRACTOR SHALL VISIT THE SITE TO VERIFY ALL CONDITIONS AND DIMENSIONS. NO EXTRAS WILL BE GIVEN FOR FAILURE TO INVESTIGATE.
2. MEANS AND METHODS ARE THE RESPONSIBILITY OF THE CONTRACTOR. INCLUDE FOR A COMPLETE INSTALLATION WITHOUT ADDITIONAL COST TO THE OWNER.
3. FIELD ORGANIZE AND INSTALL ALL EQUIPMENT, DUCTWORK, PIPING, CONDUIT, ETC FOR MAINTAIN CLEARANCE AND MAINTENANCE ACCESSIBILITY. (ALL TRADES)
4. EXISTING PIPING, DUCTWORK AND EQUIPMENT SHOWN LIGHT. NEW PIPING, DUCTWORK AND EQUIPMENT SHOWN BOLD.
5. EXISTING PIPING, DUCTWORK AND EQUIPMENT TO REMAIN OR THAT WHICH IS NOTED TO BE REVISED SHALL BE PROTECTED FROM DAMAGE.

KEY NOTES

1. DEMO AND REMOVE EXISTING BRANCH SELECTOR BOX SERVING THIS AREA. SAVE ALL EXISTING 410A REFRIGERANT FOR REINTRODUCTION BACK INTO THIS SYSTEM. TURN OVER THE BRANCH SELECTOR BOX TO THE OWNER.
2. DEMO AND REMOVE EXISTING REFRIGERANT LINES TO FAN COILS BACK TO A POINT FOR RECONNECTION AS REQ'D. SEE RENOVATION PLAN FOR CONTINUATION.
3. EXISTING LINES TO REMAIN AND TO BE CONNECTED TO THE NEW BRANCH SELECTOR BOX.



OLD STONEY REMODEL  
PHASE TWO  
120 NORTH 4TH STREET  
SUNDANCE, WYOMING 82729



PROJECT  
16-022/25004

DATE  
06-30-25

DRAWN BY  
KRD

DISK ID.

SHEET  
BASEMENT FLOOR  
ALTERNATE #6  
HYDRONIC PIPING  
DEMOLITION

SHEET

