




- GENERAL NOTES**
1. EXISTING CONDITIONS ARE BASED ON AVAILABLE INFORMATION. PRIOR TO SUBMITTING A BID, THE CONTRACTOR SHALL VISIT THE SITE TO VERIFY ALL CONDITIONS AND DIMENSIONS. NO EXTRAS WILL BE GIVEN FOR FAILURE TO INVESTIGATE.
 2. MEANS AND METHODS ARE THE RESPONSIBILITY OF THE CONTRACTOR. INCLUDE FOR A COMPLETE INSTALLATION WITHOUT ADDITIONAL COST TO THE OWNER.
 3. FIELD ORGANIZE AND INSTALL ALL EQUIPMENT, DUCTWORK, PIPING, CONDUIT, ETC. FOR MAINTAIN CLEARANCE AND MAINTENANCE ACCESSIBILITY. (ALL TRADES)
 4. EXISTING PIPING, DUCTWORK AND EQUIPMENT SHOWN LIGHT. NEW PIPING, DUCTWORK AND EQUIPMENT SHOWN BOLD.
 5. EXISTING PIPING, DUCTWORK AND EQUIPMENT TO REMAIN OR THAT WHICH IS NOTED TO BE REVISED SHALL BE PROTECTED FROM DAMAGE.

- KEY NOTES**
1. CONNECT TO EXISTING 20/4 LINED DUCTWORK UP IN CHASE, EXTEND TO SERVE ERV-2 IN THE ATTIC.
 2. INSTALL ERV-2 IN THE ATTIC COORDINATE EXACT LOCATION WITH STRUCTURAL DRAWINGS PRIOR TO INSTALLATION. ROUTE DUCTS AS SHOWN. MAINTAIN ALL MFG'S CLEARANCES AROUND THE UNIT AND THE MOTORIZED DAMPERS ON ERV. INSTALL UNIT HANG FROM THE ROOF STRUCTURE WITH VIBRATION ISOLATOR.
 3. COORDINATE EXACT DIFFUSER LAYOUT AND LOCATION OF THIS ROOM WITH EXISTING CEILING PRIOR TO INSTALLATION WITH THE ARCHITECT.
 4. INSTALL FAN COIL UNITS IN THE ATTIC SPACE. PROVIDE MFG'S CLEARANCES AROUND EACH UNIT. COORDINATE WITH ALL OTHER TRADES PRIOR TO INSTALLATION.
 5. INSTALL ELECTRIC HEATER IN THE SUPPLY AIR DUCTWORK. PROVIDE WIRING TO THE ERV-2 AND DUCT STAT AS REQ'D FOR OPERATION OF THE HEATER. OBSERVE MFG'S RECOMMENDED DISTANCES FROM THE FITTINGS.
 6. PROVIDE DRIVER BOX, CONFIRM INSTALLATION HEIGHT WITH ARCHITECTURAL PLANS. ROUTE 4" EXHAUST UP TO THE ATTIC AND TERMINATE ON THE ROOF WITH A DRIVER VENT LOW PROFILE VENT AS TO NOT CHANGE THE HISTORIC LOOK AND NATURE OF THIS BUILDING. USE NO SHEET METAL SPOWNS. PAINT VENT TO MATCH THE ROOF COLOR.
 7. REDISTRIBUTE ATTIC INSULATION ONCE THIS WORK IS COMPLETED TO RETURN IT BACK TO ITS ORIGINAL GLORY.



OLD STONEY REMODEL
PHASE TWO
120 NORTH 4TH STREET
SUNDANCE, WYOMING 82729



PROJECT
16-022/25004

DATE
06-30-25

DRAWN BY
KRD

DISK ID.

SHEET
SECOND FLOOR
HVAC

SHEET

15.40