



					<table><tr><th colspan="2">HANGER SCHEDULE</th></tr><tr><th>CARRIED MEMBER</th><th>HANGER</th></tr><tr><td>(E) JOIST - 2x12"</td><td>U210R</td></tr><tr><td>(E) JOIST - 2x4, * A < LESS THAN 12"</td><td>U24R</td></tr><tr><td>2x12</td><td>LUS210</td></tr><tr><td>(2) 2x12</td><td>LUS210-2</td></tr><tr><td>2x6</td><td>LUS26</td></tr><tr><td>(E) JOIST - GREATER THAN 2x12</td><td>CUSTOM U-R HANGER</td></tr><tr><td>2 PLY LVL</td><td>HHUS48</td></tr></table> <p>* CONTRACTOR TO VERIFY JOIST HANGER SPECIFIED FITS ACTUAL SIZES OF (E) ROUGH SAWN JOISTS; SIZES OUTSIDE OF SPECIFIED HANGER DIMENSION REQUIRE CUSTOM U-R HANGERS</p> <div><p>TO MATCH (E) ATTIC JOISTS</p><p>NEW WOOD BEAM, SEE PLAN</p><p>SIMPSON ECCQ COLUMN CAP CONNECTOR OR APPROVED EQUAL</p><p>WOOD COL, SEE PLAN</p><p>A <u>AT COLUMN SUPPORT - ISOLATED</u></p></div> <div><p>TO MATCH (E) ATTIC JOISTS</p><p>NEW OR EXISTING 2x PER PLAN</p><p>2x OR LVL PER PLAN</p><p>HANGER, SEE SCHEDULE</p><p>B <u>BEAM TO BEAM CONNECTION</u></p></div> <div><p>(E) TRUSS BOT CHORD</p><p>(E) WOOD POST</p><p>LVL PER PLAN</p><p>TO MATCH (E) ATTIC JOISTS</p><p>HANGER, SEE SCHEDULE</p><p>C <u>LVL TO (E) POST AT TRUSS BOT CHORD</u></p></div>	HANGER SCHEDULE		CARRIED MEMBER	HANGER	(E) JOIST - 2x12"	U210R	(E) JOIST - 2x4, * A < LESS THAN 12"	U24R	2x12	LUS210	(2) 2x12	LUS210-2	2x6	LUS26	(E) JOIST - GREATER THAN 2x12	CUSTOM U-R HANGER	2 PLY LVL	HHUS48
HANGER SCHEDULE																							
CARRIED MEMBER	HANGER																						
(E) JOIST - 2x12"	U210R																						
(E) JOIST - 2x4, * A < LESS THAN 12"	U24R																						
2x12	LUS210																						
(2) 2x12	LUS210-2																						
2x6	LUS26																						
(E) JOIST - GREATER THAN 2x12	CUSTOM U-R HANGER																						
2 PLY LVL	HHUS48																						
					<div><p>AT TRUSS BOT CHORD, ADD 2x BLOCKING FOR HANGER ATTACHMENT</p><p>(2) 16d x 3 1/2" NAILS OR SCREWS AT 16" OC AT NEW AND (E) BLOCKING</p><p>(E) TRUSS BOT CHORD OR ATTIC BEAM</p><p>TO MATCH (E) ATTIC JOISTS</p><p>HANGER, SEE SCHEDULE</p><p>D <u>2x TO (E) BEAM/TRUSS BOT CHORD</u></p></div> <div><p>NEW (2) 2x12 BEAM AT LOCATION OF DEMOLISHED BEARING WALL; FASTEN TO (E) BEAM AND TOGETHER WITH (2) 16d x 3 1/2" SCREWS OR NAILS</p><p>AT BM END</p><p>TO MATCH (E) ATTIC JOISTS</p><p>(E) ATTIC JOIST</p><p>HANGER, SEE SCHEDULE</p><p>E <u>NEW HEADER AT (E) ATTIC BEAM</u></p></div> <div><p>NEW HEADER BEAM</p><p>(E) ATTIC JOISTS BEYOND</p><p>TO MATCH (E) ATTIC JOISTS</p><p>A3S FROM POST TO NEW BEAM</p><p>NEW (3) 2x6 POST UNDER NEW BEAM; SHIM AS REQUIRED TO PROVIDE FULL BEARING UNDER BEAMS</p><p>STUDS NAILED TOGETHER W/ 16d x 3 1/2" NAILS AT 12" OC.</p><p>(E) ATTIC BEAM</p><p>A3S FROM (E) BEAM TO (E) TOP PLATE</p><p>(2) 16d x 3 1/2" NAILS OR SCREWS (E) TOP PL TO NEW STUD</p><p>(E) ATTIC JOISTS</p><p>NEW OR (E) TRIMMER AT END OF (E) WALL</p><p>ADD'NL 2x & BLOCKING AS REQUIRED TO PROVIDE BEARING OF (E) ATTIC BEAM</p><p>F <u>POST SUPPORT NEW HEADER AT (E) ATTIC BEAM</u></p></div>																		
					<div><div>7</div><div>NO SCALE</div><div>WOOD BEAM CONNECTION DETAILS</div></div>																		
					<div><p>DRILL PILOT HOLES INTO (E) MEMBER PRIOR TO FASTENING EA 2x4 TO (E) MEMBER WITH 4" SCREWS AT 12" OC</p><p>(E) 2x VERTICAL ROOF BEAM SUPPORTS</p><p>(2) 2x4 ATTACHED TO (E) 2x VERTICAL BEAM SUPPORT. NEW 2x4's FIT SNUG UNDER (E) ROOF BEAM</p><p>(E) 2x VERTICAL THAT EXTENDS FROM (E) BEAM OR (E) BEARING WALL SUPPORTING ATTIC FRAMING UP TO (E) WOOD BEAM AT ROOF</p><p>(E) BEAM OR WALL SUPPPTING ATTIC FRAMING</p><p>A</p></div>																		
					<div><div>4</div><div>NO SCALE</div><div>(E) VERTICAL STRUT STIFFENER</div></div>																		



OLD STONEY REMODEL
PHASE TWO
120 NORTH 4TH STREET
SUNDANCE, WYOMING 82729



PROJECT NUMBER
25-016

DATE
6/30/2025

DRAWN
MMW

DISK

SHEET TITLE
FRAMING DETAILS

SHEET NUMBER

2.40