

ADDENDUM

**PROJECT: OLD STONEY
PHASE 2
BUILDING REMODEL
PROJECT NO. 16-022**

ADDENDUM NUMBER TWO

This Addendum Number one dated Friday, July 11th, 2025 is hereby appended to and became a part of the Contract Documents for Old Stoney Phase 2 Remodel, 120 North 4th Street, Sundance, Wyoming. Drawings and specifications dated June 30th, 2025.

GENERAL

Bidder Building Access:

ADD: Bidders may arrange to visit Old Stoney for field measurements, etc. by contacting either of the below:
Melissa Gill: 307-283-3668
Amy Goodson: 307-290-0120

ARCHITECTURAL DRAWINGS

Sheet 3.00:

CHANGE: Remove hardwood flooring in areas of new Catering #215 and Janitor's Closet #221

Sheet 9.10:

CHANGE: LVT to: Shaw Contract direct glue down LVT, Terrain 11, 20 mil, 2.5 mm thickness, color: Trail 00256, and change installation to the attached detail

SPECIFICATIONS

Advertisement For Bids:

CLARIFY: Submission of Bids: Any mailed bids via U.S. Postal Service to be mailed to:

**Old Stoney
P.O. Box 1851
Sundance, Wyoming 82729**

Section 09300 - Tiling:

CHANGE: 2.03 Setting Materials: Schluter All-Set



ADDENDUM

ADDENDUM #1

Section 09300 - Tiling:

CLARIFY: Bedrosians acceptable line of tile flooring: Le Café 2" x 2" Hex, Matte Porcelain Mosaic in Black and White

LIST OF SUBCONTRACTOR ATTENDEES AT PRE-BID MEETING ON 07-10-25

COMPANY	CITY, ST	EMAIL	PHONE
Powder River HVAC	Gillette, WY	trenton@prhvac.com	307-682-3009
Scott Brothers Inc.	Gillette, WY	dan@scottbrosinc.com	307-682-5679
2 Guys Deco	Gillette, WY	twoguys@2guysdeco.com	307-660-5110
Wescom Inc	Gillette, WY	lance.koski@wescominc.com	605-641-6711
Pye Barker/Rapid Fire	Casper, WY	alex.meixell@pyebarkerfs.com	
Apex Mechanical	Gillette, WY	justin@apexmechanicalwyo.com	
Forever West Construction	Sundance, WY	calebmoeller1993@gmail.com	307-290-0445
Black Hills Hardwood Flooring	Rapid City, SD	staniferx2@hotmail.com	605-787-0010
Barton Construction	Gillette, WY	djbarton@vcn.com	307-680-2260
Van Ewing Construction	Gillette, WY	jaewing@vanewing.net	307-682-8085

ATTACHMENTS: (one) 8 ½" x 11" Sheets

END OF ADDENDUM NUMBER TWO



DIRECT GLUE DOWN LVT,
SHAW CONTRACT, TERRAIN II,
20 MIL, 2.5 MM THICKNESS,
COLOR: TRAIL 00256


SHAW 4200 RESILIENT
PREMIUM ADHESIVE

SCHLUTER STRIP, VINPRO-T,
COLOR TO BE BRUSHED
NICKEL

EXISTING HARDWOOD
FLOORING

SUBFLOOR NEW/EXISTING
CONDITION VARIES

INSTALL ADDITIONAL
UNDERLAYMENT/
PLYWOOD SUBFLOOR
(VERIFY THICKNESS) TO
MAKE LVT FLUSH WITH
ADJACENT EXISTING
HARDWOOD FLOOR



1 LVT FLOORING TRANSITION

SCALE: 6" = 1'-0"